

From: SS Inda <ssinda@bhel.in>
Sent: Wednesday, May 8, 2024 5:18:02 PM
To: Anil Jain <anil.jain@dominion-global.com>; Ankit Rai <ankit.ra@dominion-global.com>;
sipat.bhel@byggingindia.com <sipat.bhel@byggingindia.com>
Cc: subhendu.mandal@bhel.in <subhendu.mandal@bhel.in>; praveen.pandey@bhel.in
<praveen.pandey@bhel.in>; 'A K Talele(Addl GM/PMXHQ/PS-WR)' <aktalele@bhel.in>; Ram Babu
Jhalani <ram.jhalani@dominion-global.com>
Subject: Paint Brand Synorganics pvt ltd for FGD St-II sipat-reg

CAUTION External Email

Dear Sir

Based on your request for Paint Brand Name **Synorganic Paints Pvt Ltd** and submitted credentials. BHEL has submitted the credentials to EIC, NTPC and customer has accepted with necessary surveillance check (third party test) for both Chimney Shell and Flue cane.
Hence, requested to kindly arrange to supply paint with specifications as per contract.

Summary of Paint Specification:

#	Location / Structure	Product name	Paint Vendor Name
1	Chimney Shell	1. Primer Coat : EP Sealer 2. Intermediate Coat : Eptherm Phenolic 3. Finish Coat : Aliphatic Pu Finish	Synorganic Paints Pvt Ltd.
2	Flue Can	1. Primer Coat : EP ZINC RICH PRIMER 2. Intermediate Coat : EP MIO HB PRIMER 3. Finish Coat : HIGH SOLIDS PU	Synorganic Paints Pvt Ltd.

Regards
SS Inda
BHEL Sipat site
9727762755